



Length for Scab		
Pitch	TSC2.75 Piggyback (L) Design in. (mm)	TSC3.00 or TSC4.00 Piggyback (L) Design in. (mm)
3/12 (14.04°)	36 (914)	48 (1219)
4/12 (18.43°)	35 (889)	46 (1168)
5/12 (22.62°)	34 (864)	43 (1092)
6/12 (26.56°)	32 (813)	40 (1016)
7/12 (30.26°)	30 (762)	37 (940)
8/12 (33.69°)	28 (711)	34 (864)
9/12 (36.87°)	26 (660)	31 (787)
10/12 (39.81°)	23 (584)	28 (711)
11/12 (42.51°)	21 (533)	24 (610)
12/12 (45.00°)	18 (457)	21 (533)

General Notes:

1. See detail drawing number TS003 or TS003B and truss design drawing for additional connector requirements.
2. Attach 400S162-33 or 600S162-33 stud to one side of chords as shown. See chart for required stud length (L). No punchouts are allowed in this member.
3. Connect with #10 self-drilling tapping screws as shown.
4. Maximum allowable top chord gravity load for scab is 75 psf (3.59 kN/m²).
5. Wind load:
ASCE 7-05, 140 MPH (62 m/s), ASCE 7-10, 180 MPH (80 m/s) or ASCE7-16, 170 MPH (76 m/s), 30' (9144mm) mean height, closed building, Exp C, Category III - IV, $K_{zt} = 1.0$ and minimum 5 psf (0.24 kN/m²) top chord dead load to resist wind.
6. Maximum truss spacing is 4'-0" (1219mm) O.C.
7. Piggyback and/or base truss may be either TSC2.75, TSC3.00 or TSC4.00 chord material. See truss design drawings for details.
8. Base truss face and piggyback truss face must be on the same vertical plane to use this detail. See Detail A1, A2, B1 or B2 on TS003 or TS003B.



www.TrusSteel.com

Florida: 6750 Forum Drive, Suite 305 / Orlando, FL 32821 / (800) 755-6001
 Missouri: 13723 Riverport Drive, Suite 200 / Maryland Heights, MO 63043 / (800) 326-4102

Roof Deck Support On Piggyback Overhangs

Alpine, a division of ITW Building Components Group, Inc. shall not be responsible for any performance failure in a connection due to a deviation from this detail. Any variation from this detail shall be approved in advance by Alpine, a division of ITW Building Components Group, Inc.

Standard Detail:
TS003A

Date:
10/11/18

TrusSteel Detail Category:
Piggybacks