




TrusSteel Gable Truss

D = 3/8" (10mm) for TSC2.75 Gable Truss
 D = 1/2" (13mm) for TSC3.00 & TSC4.00 Gable Truss



Alternate Section A-1
 Connection to C-Web



Alternate Section A-2
 Connection to Z-Web

General Notes:

1. SDS = self-drilling tapping screw.
2. #10SDS edge distance, end distance & spacing is 9/16" (14mm).
3. Properly attached structural sheathing to the C-Stud Brace is required. Design by others.
4. This detail addresses the installation of C-Stud reinforcement to furr out and attach to structural sheathing that is flush with the face of the gable truss. No gable truss design is assumed.
5. For C-stud braces that are only required to furr out the face of the gable (i.e. not required to brace the web) 250S162-33 Grade 33 minimum shall be used and attached to the truss web with #10SDS at 6" (152mm) O.C.



www.TrusSteel.com

155 Harlem Ave., North Building, 4th Floor / Glenview, IL 60025 / (800) 755-6001

Guidelines For TrusSteel Gable Truss

(General Reinforcement Installation)

Alpine, a division of ITW Building Components Group, Inc. shall not be responsible for any performance failure in a connection due to a deviation from this detail. Any variation from this detail shall be approved in advance by Alpine, a division of ITW Building Components Group, Inc.

Standard Detail:
 TS070

Date:
 06/01/22

TrusSteel Detail Category:
 Gable Framing